



## **Declaration of Conformity**

We: **PVS nv, Veldstraat 99, 3500 Hasselt, Belgium**  
**Manufacturer of the brand CAYMON**

Declare that the following product(s):

**Brand:** CAYMON  
**Model:** SPR Series 19" Rack Cabinets  
SPR618, SPR627, SPR632, SPR642, SPR832, SPR842

To which this declaration relates is in conformity with :

- (1) The requirements of the Low Voltage Directive (LVD) 2006/95/EC
- (2) The requirements of the Construction Directive 89/106/CE – 93/68/CE

in accordance with the standards listed below :

- |     |                         |   |
|-----|-------------------------|---|
| (1) | <i>IEC 60529:</i>       | <i>Degrees of protection provided by enclosures (IP code) – IP20</i>  |
| (2) | <i>IEC 62262:</i>       | <i>Degrees of protection provided by enclosures for electrical equipment against external mechanic impacts (IK code) – IK08</i>   |
| (3) | <i>IEC 60297-3-100:</i> | <i>Mechanical structures for electronic equipment – Dimensions of mechanical structures of the 482.6 mm (19") series – Part 3-100: Basic dimensions of front panels, sub racks, chassis, racks and cabinets</i> |
| (4) | <i>EIA-310-D:</i>       | <i>Cabinet, Racks,, Panels and Associated Equipment</i>   |

***These products are intended to be installed, maintained and used by professional persons and shall be used in the application for which it is made with respect to relevant installation and manufacturer's instructions.***

Hasselt 2013-03-23

Patrick Van de Sande, Manager